

**Functional
Devices, Inc.**



TYPE F, G, EM
For use with:
Smoke Control System
General Signaling Equip. NM
Dry Indoor Use

Load
Wire



RIBMXRF

LED ON = RELAY ACTIVATED

Bulletin B520 • 393013A

SIGNALING



Functional Devices, Inc.

310 South Union Street
Russiaville, IN 46979

Phone: (765)883-5538
Fax: (765)883-7505

SENSOR OUTPUT

Maximum 30Vac/dc
Maximum .4A

SENSOR RANGE

3-150A, Maximum 150A

Factory Set Trip Point =
3A (Not Adjustable)

SENSOR INPUT

3-150A, 150A Maximum

Factory Set Trip Point =
3A (Not Adjustable)



Current Sensor Status =
Closed when LED is ON

Not Used



LED ON = Over Trip Point

www.FUNCTIONALDEVICES.com

**CAUTION: RISK OF ELECTRIC SHOCK - MORE THAN ONE DISCONNECT
MAY BE REQUIRED TO DEENERGIZE THE DEVICE BEFORE SERVICING.**