

**Functional
Devices, Inc.**



SIGNALING



RIBMXRA

LED ON = RELAY ACTIVATED

Bulletin B527 • 393018A

Functional Devices, Inc.

310 South Union Street

Russiaville, IN 46979

Phone: (765)883-5538

Fax: (765)883-7505

SENSOR OUTPUT

Maximum 30Vac/dc

Maximum .4A

SENSOR RANGE

3-150A, Maximum 150A

TYPE F, G, EM

For use with:


Smoke Control System

General Signaling Equip. NM

Dry Indoor Use



Decrease Trip Point ←
Increase Trip Point →
20 turn pot - no stop



SENSOR INPUT

3-150A, 150A Maximum



Current
Sensor
Status =
Closed
when
LED#1 is ON

LED#2 = Under Trip Point

LED#1 = Over Trip Point

Not Used



**CAUTION: RISK OF ELECTRIC SHOCK - MORE THAN ONE DISCONNECT
MAY BE REQUIRED TO DEENERGIZE THE DEVICE BEFORE SERVICING.**