

# RIBME2401SB

LED ON = RELAY ACTIVATED

Bulletin B537 • 393020A

SIGNALING



LISTED  
13CY  
15M6

TYPE F, G, EM

For use with  
Smoke Control System  
General Signaling  
Equip. NM

functionaldevices.com

Functional Devices, Inc.

310 South Union Street

Russiaville, IN 46979

Phone: (765)883-5538

Fax: (765)883-7505

CONTROL  
INPUT



## COIL

Common



5-25 Vac/dc



Common



24 Vac/dc

POWER  
INPUT



120 Vac

## CONTROL INPUT

3mA max. @ 5-25Vac/dc

## CONTACT RATINGS

20A Res. @ 277 Vac

1 HP @ 120 Vac

2 HP @ 277 Vac

20A Ballast NO @ 120/277 Vac

10A Ballast NC @ 120/277 Vac

10A Tung. NO @ 120 Vac

770 VA Pilot @ 120 Vac

1110 VA Pilot @ 277 Vac

## POWER INPUT

47mA @ 30Vdc

83mA @ 24Vac

47mA @ 120Vac



N/O



Connect Yellow Jumper Wire  
to N/O or N/C

N/C



FOR SUPPLY CONNECTIONS  
USE # 14 AWG OR LARGER  
WIRES RATED AT LEAST  
75°C (167°F).

## CONTACTS

Relay Contacts



Not Used

