

RIBME2402SB

LED ON = RELAY ACTIVATED

Bulletin B551 • 393032A



TYPE F, G, EM
For use with
Smoke Control System
General Signaling
Equip. NM

functionaldevices.com

Functional Devices, Inc.
310 South Union Street
Russiaville, IN 46979
Phone: (765)883-5538
Fax: (765)883-7505

	<u>COIL</u>
CONTROL INPUT	Common
	5-25 Vac/dc
POWER INPUT	Common
	24 Vac/dc
	208-277 Vac

CONTROL INPUT

3mA max. @ 5-25Vac/dc

CONTACT RATINGS

20A Res. @ 277 Vac
1 HP @ 120 Vac
2 HP @ 277 Vac
20A Ballast NO @ 120/277 Vac
10A Ballast NC @ 120/277 Vac
10A Tung. NO @ 120 Vac
770 VA Pilot @ 120 Vac
1110 VA Pilot @ 277 Vac

POWER INPUT

47mA @ 30Vdc
83mA @ 24Vac
69mA @ 208-277Vac



N/O

Connect Yellow Jumper Wire
to N/O or N/C

N/C



FOR SUPPLY CONNECTIONS
USE # 14 AWG OR LARGER
WIRES RATED AT LEAST
75°C (167°F).

CONTACTS

Relay Contacts

Not Used

