

- Ideal for stagger-starting multiple rooftop units
- No 5 minute delay typical to Delay on Make timers


### MODE OF OPERATION

Upon initial application of power, the delay on make period is initiated. Once the delay is complete, the unit will be energized.

#### Lockout:

Upon application of power, the load is energized. Upon opening the thermostat, or loss of power, the load is de-energized and the period begins. The compressor will not start again during the delay period.

### TIMING DIAGRAM



### INSTALLATION

1. Disconnect power.
2. Connect terminals as shown in the system diagram below.
3. Select desired time delay.
4. Reapply power, check operation.

### SPECIFICATIONS

#### Input

- **Voltage:** 18-30 VAC
- **Frequency:** 50-60 Hz

#### Output

- **Output Ratings:**
  - **Maximum:** 1 amp
  - **Minimum:** 40 mA
  - **Inrush:** 10 amps

#### Time Delay

- **Lockout:** Knob adjustable (6-600 seconds)
- **Random Start:** 10% of selected lockout time

### WIRING DIAGRAM

